



## CENTRAL BOARD OF SECONDARY EDUCATION

(An Autonomous Organization under the Union Ministry of Human Resource Development, Govt. of India)  
"Shiksha Sadan", 17 Rouse Avenue, New Delhi - 110002 .

F-445C/Maint./2014/  
.....  
.....  
.....

Dt. 11/08/2014

**Sub:- Short term limited tender for SITC of Electrical work i/c Servicing & repairing of LT Electric Panel .**

Sir,

The Board intends to invite short term Limited Tender for "SITC of Electrical work i/c servicing & repairing of LT Electric panel installed at CBSE, Shiksha Sadan building." from specialized agencies having executed minimum 3 works of equivalent magnitude. An EMD of Rs 8000/- in the form of DD/BD payable to the Secretary, CBSE and experience documents be attached along with the quotation format. Sealed tender complete in all respect must be submitted latest by 26/08/2014 upto 2p.m. & dropped in the tender box placed at Reception counter, Shiksha Sadan, 17 Rouse Avenue, Delhi-110002. Sealed quotations shall be opened on same day at 3:00 PM in the presence of tenderers.

Incomplete & conditional quotations shall be summarily rejected. The Secretary CBSE reserves the right to reject any or all the quotations without assigning any reason-thereof.

Yours faithfully

**(RAHUL TYAGI)**  
**JUNIOR ENGINEER (CIVIL)**

**CENTRAL BOARD OF SECONDARY EDUCATION,  
17 Rouse Avenue, New Delhi- 110002**

**Last Date for submission :26/08/2014.  
Upto 2.30 P.M.**

Name of work: **Limited Tender for SITC of Electrical work i/c Servicing  
& repairing of LT Electric Panel .**

**1. Credentials of tenderer**

1.1 Name of the Agency : \_\_\_\_\_

1.2 Office Address and  
Tel.Nos. \_\_\_\_\_

1.3 Licence No. & Registration  
details(with documentary  
evidence) \_\_\_\_\_

1.4 P.F. A/c No.  
(With documentary evidence) \_\_\_\_\_

1.5 PAN No.  
( with documentary evidence) \_\_\_\_\_

1.6 Service Tax Regd. Certificate:  
(supported with documentary evidence)\_\_\_\_\_

2. Annual turnover for last three years  
supported with documentary evidence)\_\_\_\_\_

3. Experience (last three years) \_\_\_\_\_

3.1 Contract details fulfilling eligibility criteria

S.No.	Year	Name of the Organization	Cost of the work (Executed )	Officer Concd. in the Organization with T.No.	Period From	To
01.						
02.						
03.						

3.2. Present assignment in hand complying tender parameters: particularly in multi-storied bldgs. (Supported with documentary evidence)

(i)

- (ii)
- (iii)

3.3 Manpower details in terms of supervisors, & staff

**3.5 Earnest Money Deposit (EMD)**

1. The Govt. Departments, Public Sector Units, Small Scale Industrial (SSI) Units (only permanently registered) & agencies registered with NSIC etc., are exempted from submitting EMD.
2. SSI Units and agencies requesting for exemption from submission of EMD shall submit a copy of their Registration Certificate.  
Only such SSI Units and agencies registered for the same trade/Item for which the tender is relevant shall be exempted from submission of EMD.
3. EMDs of unsuccessful tenders shall be refunded after reasonable time without interest.
4. The tenders without EMD or partial EMD shall be summarily rejected.

4. Particulars of D.D. as earnest money:

Amount Rs. : \_\_\_\_\_

D.D/B.D Nos. : \_\_\_\_\_

Issuing Bank with

Date of Issue : \_\_\_\_\_

\_\_\_\_\_

5. The Financial-Bid of the prequalifying agencies shall only be opened.

6. Copy of the documents at Serial Nos.1.3 to 3.5 be attached.

**Declaration:** All terms and conditions as mentioned in the tender are acceptable to me/us.

**(Signature of the Tenderer)**  
**With complete address and seal**

**Tel. No.:** \_\_\_\_\_

**Mobile No.:** \_\_\_\_\_

**Place:** \_\_\_\_\_

**Date :** \_\_\_\_\_

## PRICE SCHEDULE

**Name of work:- SITC of Electrical work i/c Servicing & repairing of LT Electric Panel .**

S.NO	DESCRIPTION OF ITEM	QTY.	UNIT	RATE	AMOUNT
1.	Supplying and fixing of following ways surface/ recess mounting, vertical type, 415 volts, TPN MCB distribution board of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, din bar for mounting MCB's (but without MCB's and incomer ) as required . (Note : Vertical type MCB TPDB is normally used where 3 phaseoutlets are required.) (MAke :- ABB, Legrand, L&T and Standerd) 8 way (4 + 24), Double door	1	Each		
2.	Wiring for circuit/ submain wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required 4 X 10 sq. mm + 2 X 10 sq. mm earth wire 2 X 6 sq. mm + 1 X 6 sq. mm earth wire	60 120	Metre Metre		
3.	Supplying and fixing following way, horizontal type three pole and neutral, sheet steel, MCB distribution board, 415 volts, on surface/recess, complete with ned copper bus bar, neutral bus bar,earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) 4 way (4 + 12), Double door	4	Each		
4.	Providing and fixing following rating and breaking capacity and pole MCCB in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required. 100 Amp, 16 KA,TPMCCB	1	Each		
5.	Supplying and fixing 15 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the				

	existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole Double pole Triple pole	48 04 08	Each Each Each		
6.	Supplying and fixing 20 amps, 240 volts, SPN industrial type , socket outlet, with 2 pole and earth, metal enclosed plug top alongwith 20 amps "C" curve, SP, MCB, in sheet steel enclosure, on surface or in recess, with chained metal cover for the socket out let and complete with connections, testing and commissioning etc. as required.	10	Each		
7.	Testing resistance of Earth pits with the suitable measuring instruments i/c providing test report complete as required.	05	Each		
8.	Providing and fixing of following items i/c removal of old defective and fixing the new complete with control wiring etc. as requiredat site.				
	Ampere Meter	3	Each		
	Volt Meter	3	Each		
	Indicating Lamp	6	Each		
	Amp Selector switch	5	Each		
9.	Servicing of 100/200 Amp, 415volt Fixed type, 3 phase 4 wire, 50 Hz Ac Supply LT MCCBs complete with removal from LT panel board, opening / dismantling the required parts for servicing, checking cleaning, testing and rectification the defects, assembling Complete as required.	1	Job work		
10.	Providing and Fixing of Thimbles in Existing cable i/c removal of old Burnt and cleaning the leads terminals with the help of chemical i/c The Proper Electrical loads settings of different Switches MCCB,s complete service & over Holing testing for Suitable size etc. testing commissioning complete as required.	1	Job work		
11.	Painting of 2nos existing LT cubical panel with two or more coats of enameled paint i/c sign writing.	1	Job work		

**GROSS AMOUNT:.....**

Accepted by me:

**Signature  
Prop./ Manager  
Tel. No.  
Mob. No.**

## **TERMS & CONDITIONS**

1. The work should be executed as per CPWD specifications and as per directions of Engineer-In-Charge.
2. All T & P shall be arranged by the Contractor.
3. The materials to be used must be got approved from the Engineer-in-charge before installation/use.
4. The agency shall take all precautionary measures for safety of his workers during Performance of the work.
5. The work is to be completed within a period of 15 days after 7<sup>th</sup> day of the work order.
6. The work shall not be discontinued at any cost.
7. The agency shall get the samples of the material approved in advance before utilization.
8. The workmanship must be excellent. In case of poor workmanship, the Board shall be free to cancel the contract.
9. The agency shall ensure that the wages to the workmen are paid according to  
Minimum wages prescribed by the Govt. of N.C.T. Delhi.
10. The work shall be executed under the strict supervision of the Board's J.E.
11. In case of delay, a penalty @ 1% per week shall be levied subject to a max of 5%.
12. In case of poor workmanship, the Board shall have the right to rescind the contract and get the work executed through any other agency at the risk & cost of the defaulting contractor.
13. In case the work is kept suspended without any valid reason, the Board shall be free to get the remaining work executed through any other agency.
14. The contractor shall be required to provide adequate safety for its workers and the Board shall not be accountable to any kind of injury/ accident at site.
15. The agency shall be solely responsible for any damage/loss to the Board's Property / equipment's.
16. The elect, Copper shall be of Kalinga/Havell's/Plaza/Anchor/Finolex.
17. The agency must be CPRI approved and the product must comply the norms.

Accepted by me:

Signature  
**Prop./ Manager**  
**Tel. No.**  
**Mob. No.**