



CENTRAL BOARD OF SECONDARY EDUCATION

(An Autonomous Organization under the Union Ministry of Human Resource Development, Govt. of India)
"Shiksha Kendra", 2 Community Centre, Preet Vihar, New Delhi - 110092 .

F-2019/CET Pune/Maint.(H.Q)/2015

Dt. 03/03/2015

.....
.....
.....
.....

Sub.: limited Tender for SITC of Air Conditioning Work at CET Pune.

Sir,

The Board intends to get executed the work of **SITC of Air Conditioning Work in CET Pune** located at Shopper's orbit, 316-C 3rd floor, Visharantwadi Pune from specialized agencies. An EMD of Rs.20,000/- in the form of DD/BD payable to the Secretary, CBSE Delhi and experience documents be attached along with the tender.

Sealed tenders superscribed "SITC of Air Conditioning Work at CET Pune" complete in all respect may be sent to Joint Secretary (A&L), on or before 17.03.2015 upto 03:00 P.M. Quotations which are either late or incomplete shall be summarily rejected.

The Secretary, CBSE reserves the right to reject any or all the tenders without assigning any reason thereof.

(V.N. Mishra)
AE (civil)

Schedule of work

Name of Work: SITC of Air Conditioning Work at CET Pune.

S.No	Description of item	Qty	Unit	Rate Inclusive of all taxes (In Rs.)	Amount (In Rs.)
1.	<p>SITC of High wall split type following capacity air conditioners with one indoor evaporating unit and one condensing unit with rotary type compressor including all accessories and suitable for operating voltage 220V +/- 10% 50Hz +/-3% . The unit should be of high cooling performance, energy efficient complete with filling of R-22 refrigeration gas and sturdy for continuous operation and also with rust proof cabinet with sturdy front panel /grills must have auto swing and flush lowers etc. for horizontal and vertical air throws with including 5 m copper refrigerant, gas charging drain pipe and required electrical cabling with remote control etc. (Minimum 3 star rating). Make: HITACHI/CARRIER/VOLTAS/BLUESTAR. The rate inclusive of regular one year Warranty with three free services.</p> <p>(A) 1.5TR</p> <p>The rate inclusive of regular one year Warranty with three free services.</p>	8Nos.	Each		
2.	<p>SITC of ceiling mounted Cassette Unit 2.0 TR capacity air conditioner with one condensing unit, rotary type compressor including all accessories and suitable for operating voltage 220V +/- 10% 50Hz +/-3% . The unit should be of high cooling performance, energy efficient complete with filling of R-22 refrigeration gas and sturdy for continuous operation and also with rust proof cabinet with sturdy front panel /grills, for smooth air throws including 5 m copper refrigerant, gas charging drain pipe and required electrical cabling with remote control etc. (Minimum 3 star rating). Make: HITACHI/CARRIER/VOLTAS/BLUESTAR. The rate inclusive of regular one year Warranty with three free services.</p>	8No.	Each		

3.	Supply & Installation of Wall mounted following capacity automatic Voltage stabilizer of 170V to 270 range single Phase AC supply. (a) 4KVA	8Nos.	Each		
	(b) 5KVA	8Nos.	Each		
4.	Supply & Installation of 2mm thick PVC Drain pipes of suitable size in order to effectively drain out water as directed at site.	70	Mts.		
5.	Supply & Fixing of angle iron frame as per site requirement and direction of Engineer incharge.	16.	Nos		
6.	Supply & Laying of additional refrigerant copper piping for 1.5TR/2TR split AC unit	45	Mts.		
7.	Providing and fixing suitable size additional electrical cable for the outdoor unit.	Rate only	Rmt		
8.	PVC Channel for covering of Copper pipe	Rate only	Rmt		
9.	Supply and fitting of Outdoor stand	16	Each		
10.	Power plug 3 pin	18	Each		
TOTAL					

Terms and Conditions

1. The work should be executed as per CPWD specifications and as per directions of Engineer-in-charge.
2. The rate shall be firm and of inclusive all taxes and valid for a period of 60 days from the date of the tender.
3. The completion time would be 20 days.
4. In case of delay, a penalty of 1% per week should be deducted. Subjected to a max of 5% of the tender value.
5. The measurement shall be done jointly
6. All T&P shall be arranged by the Contractor.
7. 25% deviation in quantities would be permitted.
8. Extra-item if any would be paid on analyzed Market rates but the work must be executed with prior approval of the Engineer-in-charge.
9. In case of any dispute, the Arbitrator shall be appointed by the Chairman and his decision shall be binding.
10. The materials to be used must be got approved from the engineer-in-charge before installation/use. In no case, unspecified material shall be brought at site.
11. The electrical items/materials must comply the IS Standards/the approved brands.
12. The elect. Copper cables shall be of Kalinga/ Havell's/Plaza Anchor/Finolex.
13. Modular type switches shall be of Havell's / Anchor /Northwest/Legrand.
14. The TPN/DB/MDB/MCB's shall be of Havell's/ Anchor/Standard/Hager/L&T/EE.
15. The agency shall not delay/stop the work without any valid reason.
16. In case of no/slow progress, inferior workmanship, the Board shall have the right to rescind the contract & get the work executed at the risk & cost of the defaulting agency.

(Signature of the Agency)
With complete address and seal
Add. _____

Tel. No.: _____
Mobile No.: _____